

HEATING AND AIR CONDITIONING

20. Has heating and air conditioning equipment been inspected by a qualified service technician in the past year? Yes No N/A _____

21. Is the boiler/furnace room in a separate, fire resistant enclosure? Yes No N/A _____

22. Is the boiler/furnace room equipped with a self-closing fire door? Yes No N/A _____

23. Is the boiler/furnace room free of paper, trash and flammable liquids? Yes No N/A _____

24. Does the oil/gas burner have a clearly identified emergency switch? Yes No N/A _____

FIRE PREVENTION SYSTEM

25. Are there enough fire extinguishers to satisfy local fire codes, and are those extinguishers easily accessible? Yes No N/A _____

26. Have fire extinguishers been inspected or recharged within the year and tagged accordingly? Yes No N/A _____

27. Have the automatic sprinklers and hose systems been inspected and maintained within the year? Yes No N/A _____

28. Are smoke detectors present in every room of the Chapter house (mandated by the 140th Congress) Yes No N/A _____

NOTES: _____

